

# Certificate of constancy of performance

No. 0672-CPR-0050

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the

Construction Product(s) **Overhead door closer**  
**„GEZE TS 4000“, „GEZE TS 4000 S“ and**  
**„GEZE TS 4000 EN 5-7“**

**with the classification enclosed in the annex 1 of this certificate**

placed on the market  
under the name or trade  
mark of

**GEZE GmbH**  
**Reinhold-Vöster-Str. 21-29**  
**71229 Leonberg**  
**Germany**

produced in the  
manufacturing plant(s)

**Plant 01**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in

Annex ZA  
of the standard(s)

**EN 1154:1996/A1:2002/AC:2006**

under system


**1**

for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

**constancy of performance of the construction product.**

This certificate was first issued on **23.10.2017** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

This document has been translated for informative purpose only. Original version is issued in German. In any case of doubt the German version is valid.



(Stamp)

Stuttgart, 23.10.2017

A handwritten signature in blue ink, appearing to read 'Stefan Lehner'.

Dr. rer. nat. Stefan Lehner  
Head of Certification Body



### Annex 1

to the certificate of constancy of performance No. 0672-CPR-0050

#### Classification of the door closers\*

GEZE TS 4000	EN 1154	4	8	6 1	1	1	4
--------------	---------	---	---	--------	---	---	---

GEZE TS 4000 S	EN 1154	4	8	6 2	1	1	4
----------------	---------	---	---	--------	---	---	---

GEZE TS 4000 EN 5-7	EN 1154	4	8	7 5	1	1	4
---------------------	---------	---	---	--------	---	---	---

#### Mounting with guide rail:

GEZE TS 4000	EN 1154	4	8	3 1	1	1	4
--------------	---------	---	---	--------	---	---	---

GEZE TS 4000 S	EN 1154	4	8	3 2	1	1	4
----------------	---------	---	---	--------	---	---	---

\* The assembly of these door closers can be carried out in normal, frame or parallel arm mounting.

**Note:** The manufacturer has to point out in the assembly and adjustment documents of the door closer, that the door closer should be at least on size 3 for use on fire/smoke door assemblies.

Stuttgart, 23.10.2017

Material Testing Institute – University of Stuttgart  
Department Fire Safety  
Certification Body



(Dr. rer. nat. Stefan Lehner)  
Head of the Certification Body

